

TO WHOM SO EVER IT MAY CONCERN

HEALTH AND SANITARY CONDITION OF DON BOSCO CONVENT SCHOOL, BASUARA,  
MADHUBANI (BIHAR)-847212

THIS IS TO CERTIFY THAT DON BOSCO CONVENT SCHOOL, BASUARA, MADHUBANI (BIHAR)-847212 HAS SATISFACTORY ARRANGMENTS OF DRINKING WATER. THE HYGINE OF THE SCHOOL IS SATISFACTORY. THE CAMPUS OF THE SCHOOL IS FREE FROM SANITATION PROBLEM.

PLACE : MADHUBANI

DATE: 10/02/2022.

*Caran Singh*  
10/02/2022  
Lab. Asst.  
CHEMIST  
P.H.E.D. Madhubani  
P.H.E.D. MADHUBANI

# DISTRICT LEVEL WATER TESTING LABORATORY


## P.H.DIVISION, MADHUBANI

District-Madhubani

Month- Feb. 2022

S. N	Block	Panchayat	Village	Name of Habitation	Near est person	PH	TURBIDITY	TOTAL HARDNESS	TOTAL ALKALINITY	CALCIUM	MAGNESIUM	CHLORIDE	IRON	FERRIC	SULFATE	NITRATE	TDS	MPN	REMARKS
1.	Rohika	Balkhama	Badhaha	DON BOSCO CONVENT SCHOOL.	(LHP)	7.49	1	200	216	46.4	36.81	32	0.32	NT	NIL	130	305	A	425 Safe
Min-Max Permissible LIMIT						6.5-8.5	00-0.5	300-600	200-600	75-200	30-100	250-1000	.3-1.0	6-1.5	150-400	45	500-1500		

THIS WATER IS SAFE FOR DRINKING PURPOSE

  
 10/02/2022.  
 Lab. Asst. CHEMIST  
 P.H. Division, Madhubani  
 P.H.DIVISION MADHUBANI